



Nestekaasun turvallinen käsittely ja säilytys ravintoloissa ja lounaspaikoissa

Nestekaasun käyttölaitteiden on oltava sisätiloihin hyväksytyjä. CE-merkintä osoittaa laitteen täyttävän sitä koskevat turvallisuusvaatimukset. Nestekaasun käyttölaitteisiin liittyviä kiinteitä asennuksia saa tehdä ja huoltaa vain Tukesin hyväksymä kaasuasennusliike.

Kaasukeittimen ja kaasuhellan pakolliset varusteet ovat

- 🚫 liekinvalvontalaite
- 🚫 letkurikkoventtiili
- 🚫 nestekaasuletku, pituus enintään 1,2 metriä

Nestekaasun säilytys ravintolassa

- 🚫 enintään 25 kg kerralla
- 🚫 kaasupullon koko enintään 11 kg
- 🚫 esimerkki: 2 kpl 11 kg kaasupulloa
(myös tyhjä pullo lasketaan määrään)
- 🚫 tuulettuvassa tilassa
- 🚫 kaasupullo aina pystyasennossa



Nestekaasun säilytys on kielletty

- ❌ kellarissa
- ❌ muissa maanalaisissa tiloissa
- ❌ ullakotiloissa
- ❌ poistumisreiteillä
- ❌ kuumassa tilassa, kuten sähkö- tai puuhellan vieressä

Mikäli nestekaasua on tarve säilyttää enemmän kuin 25 kg, tällöin täydet ja tyhjat pullot säilytetään ulkona **kaasupullokaapissa**, jossa on

- 🚫 lukko
- 🚫 tuuletus
- 🚫 ”kaasupullot” – merkki
- 🚫 ”tupakointi ja avotulen teko kielletty” – merkki
- 🚫 täydet ja tyhjat pullot pystyasennossa suojahatut kiinnitettyinä
- 🚫 täydet ja tyhjat pullot merkittyinä



Kaasupullokaappi

Kaasupullokaapissa ei saa säilyttää muuta tavaraa.

Perusteet: Valtioneuvoston asetus nestekaasulaitosten turvallisuusvaatimuksista 858/2012, Valtioneuvoston asetus vaarallisten kemikaalien käsittelyn ja varastoinnin valvonnasta 685/2015



Guide: How to handle and store burning gases safely in restaurants and lunch counters

Liquid gas is used in gas cookers, which must be accepted for inside use. CE-mark shows, that the gas cooker fulfills safety requirements. Note, that only gas installation companies (approved by Tukes) may carry out fixed installations and maintain equipment.

Obligatory equipment for gas cookers are

- ✔ a flame monitoring device
- ✔ a safety valve, which prevents a gas leakage from the broken gas tube
- ✔ a gas tube, maximum length of tube is 1,2 meters

Storage of liquid gas inside the restaurant

- ✔ max. 25 kg at the same time
- ✔ maximum size of a gas bottle is 11 kg
- ✔ example: You can have only two 11 kg bottles.
Note, the empty bottle is also included in the amount
- ✔ in a ventilated space
- ✔ a gas bottle always in an upright position



Storage of gas bottles is forbidden

- ✘ in a cellar
- ✘ in other underground spaces
- ✘ in an upstairs storage
- ✘ in exit gateways
- ✘ in a hot space, like next to an electric oven or a wood-burning stove

Note, if it is necessary to store more than 25 kg of gas, You must store the gas bottles outside the building in a separate **gas bottle storage** (also empty bottles):

- ✔ a storage is locked and ventilated
- ✔ a storage is supplied with texts:
*“gas bottles”, and
“smoking and open fire forbidden”*
- ✔ full and empty bottles are stored in an upright position,
“a safety hat” attached to a valve
- ✔ full and empty bottles are marked or stored in different parts of a storage



A separate gas bottle storage

Do not store other stuff in a gas bottle storage.